

DEPARTMENT OF THE ARMY  
Omaha District, Corps of Engineers  
106 South 15th Street  
Omaha, Nebraska 68102-1618

---

:NOTICE: Failure to acknowledge :	Solicitation No. DACW45 02 B 0016
:all amendments may cause rejec- :	
:tion of the bid. See FAR :	Date of Issue: 28 May 2002
:52.214-3 of Section 00100 :	Date of Opening: 01 Jul 2002

---

Amendment No. 0003  
26 June 2002

SUBJECT: Amendment No. 0003 to Specifications and Drawings for Construction of  
South Platte River Visitor Center Rehab, Chatfield Project,  
Littleton, CO.  
Solicitation No. DACW45 02 B 0016.

TO: Prospective Bidders and Others Concerned

1. The specifications and drawings for subject project are hereby modified as follows (revise all specification indices, attachment lists, and drawing indices accordingly).

a. Specifications. (Descriptive Changes.)

(1) Section 15700A, page 8, delete paragraphs 2.4.6 and 2.4.7 and substitute the following:

"2.4.6 Controls

Unit shall be provided with a non-fused disconnect switch. Unit shall be completely factory wired. Control system shall be microprocessor based and fully, integrated to control rooftop unit function in coordination with system bypass box and zone damper controllers. A control panel will be provided in the NE wall of the electrical room where the status of the rooftop unit, bypass box and zone dampers controller can be accessed and diagnosed. The rooftop unit and zone thermostat function will be switched from heating to cooling at this control panel. See Drawing on sheet M5.01 for additional control information.

2.4.7 Zone Thermostats

Provide combination heating-cooling type zone thermostats with contacts hermetically sealed against moisture, corrosion, dust and foreign materials. This option shall be available with automatic night setback, and malfunction light.

2.4.7.1 Bypass Box

By pass box shall be sized to bypass between 0 to 2500 CFM at a velocity not to exceed 1800 FPM. Bypass box shall be provided by rooftop manufacturers."

b. Drawings (Not Reissued). The following drawing sheets are revised as indicated below with latest revision date of 26 June 2002. These drawings are not reissued with this amendment.

(1) Sheet M5.01- see SEQUENCE OF OPERATION:

a) Delete the 2<sup>nd</sup> Sentence and substitute the following:  
"ZONE DAMPERS SHALL MODULATE TO AMINTAIN TEMPERATURE SETPOINT (ADJUSTABLE) OF  
ZONE THERMOSTAT".

b) 6<sup>th</sup> Sentence: delete "SHALL BE PROVIDED BY  
MANUFACTURER'S STANDARD CONTROL PACKAGE" and substitute "CONTROL SHALL BE  
INTEGRATED WITH BUILDING TEMPERATURE CONTROL".

2. This amendment is a part of the bidding papers and its receipt shall be acknowledged on the Standard Form 1442. All other conditions and requirements of the specifications remain unchanged. If the bids have been mailed prior to receiving this amendment, you will notify the office where bids are opened, in the specified manner, immediately of its receipt and of any changes in your bid occasioned thereby.

a. Hand-Carried Bids shall be delivered to the U.S. Army Corps of Engineers, Omaha District, Contracting Division (Room 301), 106 South 15th Street, Omaha, Nebraska 68102-1618.

b. Mailed Bids shall be addressed as noted in Item 8 on Page 00010-1 of Standard Form 1442.

3. Bids will be received until 2:00 p.m., local time at place of bid opening, 01 July 2002.

U.S. Army Engineer District, Omaha  
Corps of Engineers  
106 South 15th Street  
Omaha, Nebraska 68102-1618

26 June 2002  
MFS/4411